

ADEQ

ARKANSAS
Department of Environmental Quality

FEB 05 2019

Charles W. Maguire, Director
Water Quality Protection Division (6WQ)
U.S. Environmental Protection Agency, Region 6
1445 Ross Avenue, Suite 1200
Dallas, TX 75202-2733

RE: February 2019 Water Quality Management Plan Governor Certification


Dear Director Maguire:

Pursuant to the authority given to me by Governor Asa Hutchinson, I hereby certify that the Arkansas Water Quality Management Plan (WQMP) is current and has been updated as needed pursuant to Section 208 of the Clean Water Act and 40 CFR §130.6(e). These updates have been made available for public comment pursuant to 40 CFR §124.10. The WQMP is updated as needed as permits are issued, renewed, modified, or terminated. The current WQMP may be viewed at: <https://www.adeq.state.ar.us/downloads/water/NPDES/WQMP.xls>.

The previously submitted Arkansas Governor's certification was dated September 20, 2017, and was formally approved by EPA on November 2, 2017. The enclosed table lists all facilities that have had changes in the WQMP since the last certification, and these changes are indicated in the last column of the table.

If there are any questions, please contact Shane Byrum of my staff at (501) 682-0618 or byrum@adeq.state.ar.us.

Sincerely,



Becky W. Keogh
Director

Enclosure: February 2019 Governor Certification (Table 1)

cc: Syed A. Shahriyar, Regional Coordinator, WQMP Program, EPA Region 6
Shane Byrum, Engineer, Permits Branch, Office of Water Quality, ADEQ
Carrie McWilliams, P.E., Engineer Supervisor, Office of Water Quality, ADEQ
Bryan Leamons, P.E., Senior Operations Manager, Office of Water Quality, ADEQ
Bob Blanz, P.E., Ph.D., Chief Technical Officer, ADEQ
Caleb Osborne, Associate Director, Office of Water Quality, ADEQ

Table 1
Arkansas Department of Environmental Quality
Water Quality Management Plan Governor Certification
February 2019

NPDES#	Facility Name	Receiving Stream	Q mgd	Critical Limits (May-Oct.)					Seasonal Limits (Nov-Apr)					TMDL based limits	Changes Prompting Gov Cert
				CBOD ₅	TSS	NH ₃ N	DO	TP	CBOD ₅	TSS	NH ₃ N (Nov-Mar)	NH ₃ N (April)	DO		
AR0046604	Amagon	Un. Trib./Cache River	0.016	20	20	5	3.0		20	20	12	5.2	2.0		No record of previous Gov Cert approval.
AR0050806	Arkansas Conference Association of Seventh Day Adventists d/b/a Camp Yorktown Bay	Lake Ouachita	0.006	10	15	5	6.0	Report	10	15	10	5.2	6.0	Report	DO limit revised.
AR0037061	Ark. Dept. of Parks - Lake Degray State Park	Lake DeGray	002: 0.1 003: 0.009	10	15	5	5.0	1.0	10	15	10	5.2	5.0	1.0	Design flow corrected for outfall 002.
AR0049620	Arkavally Airpark	Trib./East Fork Cadron C	0.011	15	20	5	3.0	1.0	15	20	12	5.6	3.0	1.0	TP limits added.
AR0042846	Ash Grove Cement (Outfall 003)	Un. Trib./French Creek	3.36	10 (BOD5)	50 (max)		2.0		10 (BOD5)	50 (max)			5.0		Outfall 003 flow changed.
AR0042951	Ashdown	Red River	1.1	30 (BOD5)	90		2.0		Year-round						TMDL limits for Chloride, Sulfate, TDS removed from WQMP. TMDL withdrawn 11/9/2018.
AR0038369	Austin	Four Mile Creek	0.136	15	20	4	5.0		25	30	10	5.6	4.0	FCB: 1270 Mcol/day (Apr-Sep) FCB: 3180 Mcol/day (Oct-Mar)	Facility flow changed.
AR0038270	Baker Hughes Oilfield Operations LLC - Fancy Hill Operations	Back Valley Creek/South Fork Caddo River	14.076											Total Copper: 1.204 lb/day Total Zinc: 10.601 lb/day	Facility added with TMDL limits for Copper and Zinc.
AR0041688	Blevins	Un. Trib./Ozan Cr/L.Mo.R	0.08	No discharge allowed May-October					25	45	12	6.1	5.0		CBOD5 and TSS limit revised.
AR0050911	Bradford	Butter Creek	0.2	15	20	5	3.0		20	20	10	5.2	3.0		No record of previous Gov Cert approval.
AR0045284	Cash	Un. Trib./Tupelo Slough	0.048	10	15	5	2.0		10	15	10	5.2	2.0		Facility flow changed, receiving stream name corrected.
AR0041289	Cedarville Public Schools	Un Trib of Little Webber Creek	0.02	20	20	5	5.0		25	30	15	5.3	5.0		Facility flow changed.
AR0050539	Pinewood Wastewater, LLC dba Pinewood Estates Subdivision	Un trib/Panther Creek	0.05	15	20	5	5.0		15	20	10	5.2	2.0		CBOD5 limit corrected for Nov-Apr.
AR0051942	SamSand, LLC	Red River	0.1												TMDL limit for Chloride and TDS removed from WQMP. TMDL withdrawn.
AR0022187	Clarksville (Outfall 002)	Spadra Creek	HCR	25	90	13.6	2.0	Report	30 (BOD5) 25 (CBOD5) (April)	90		13.6	2.0	Report	CBOD5 replaced BOD5, added NH3 limit.
AR0033979	Corning, City of	Black River	0.89	30 (BOD5)	90		2.0		Year-round						No record of previous Gov Cert approval.
AR0000591	Martin Operating Partnership L.P.	Smackover Creek	0.238 (May-Oct) 0.297 (Nov-Apr)	12		4.2	4.0		30		15	15	3.2		NH3 limit changed for May-October. Facility flow changed.
AR0022292	Decatur	Columbia Hollow Creek	3.8	10	15	1.6	6.0	0.5	10	15	4.1	1.7	6.3	0.5	Facility flow revised, Nov-Apr DO limit change, April NH3 limit change, TP limit change.
AR0021709	Dierks	Holly Creek	0.23	10	15	5	5.0		20	20	8	6.1	5.0	FCB: 3,480 Mcol/day (May-Sep) FCB: 17,400 Mcol/day (Oct-Apr)	TMDL limits for FCB added.
AR0048411	Domtar A.W. LLC - Ashdown Woodyard Wet Deck	Un. Trib./Hudson Creek	0.055	30 (BOD5)	35		3.0		30 (BOD5)	35			3.0		Facility added to WQMP.
AR0002968	Domtar Industries Inc. - Ashdown	Red River	56.4	BOD5: Aug;>29C=7.6#/cfs, 27C-28.9C=11.4#/cfs, <26.9C=16#/cfs BOD5: Sep;>27C=7.3#/cfs,24C-26.9C=9.9#/cfs,<23.9C=14.7#/cfs BOD5: Oct;>20C=15.8#/cfs,<19.9C=20#/cfs BOD5: November-July, 36,191 lb/day											TMDL limits for TDS, Sulfate, Chloride were removed from WQMP. TMDL withdrawn 11/9/2018.
AR0042862	Sheridan School District #37 East End Schools	McCright Branch	0.04	20	40	5	2.0		30 (BOD5)	90			2.0		No record of previous Gov Cert approval.
AR0044938	O.K. Foods - Ft. Smith Wastewater Treatment Facility	Arkansas River	3.5	13.7	16.8	3.4	2.0		Year-round						Facility name change, BOD5 and TSS limits changed.

Table 1
Arkansas Department of Environmental Quality
Water Quality Management Plan Governor Certification
February 2019

NPDES#	Facility Name	Receiving Stream	Q mgd	Critical Limits (May-Oct.)					Seasonal Limits (Nov-Apr)					TMDL based limits	Changes Prompting Gov Cert		
				CBOD ₅	TSS	NH ₃ -N	DO	TP	CBOD ₅	TSS	NH ₃ -N (Nov-Mar)	NH ₃ -N (April)	DO			TP	
AR0000493 (terminated)	Entergy-Harvey Coueh Plant	Trib/Lake June	0.382												Total Cu: 0.02899 lb/day, 9.09 ug/l Total Pb: 0.0085 lb/day, 2.67 ug/l	Removed from WQMP. Permit terminated on 12/18/2017.	
AR0050741	Etowah	Right Hand Chute of Little River Floodway Ditch	0.07	30 (BOD5)	90		5.0		Year-round							TSS limit revised.	
AR0021865	Eureka Springs	Leatherwood Creek	0.9	10	15	2.5	6.5	1.0	10	15	5	3.9	6.5	1.0		NH3-N limit added for April.	
AR0020010	Fayetteville-Noland Outfall 001	White River	12.6	Apr-May 7.5	Apr-May 5	Apr-May 2.1	Apr-May 7.7	Apr-May 1.0	Jun-Sept 5.7	Jun-Sept 5	Jun-Sept 0.5		Jun-Sept 11.0	Jun-Sept 1.0		CBOD5, NH3-N, DO limit changes, facility flow change, updated model.	
AR0021717	Flippin	Fallen Ash Creek	0.175	10	15	2	6.0		10	15	9	4	6.0			NH3 and DO limits revised.	
AR0000612	Firestone Building Products Compa	Un. Trib./Garland Creek	0.074	20	20	5	3.0		20	20	13	6.1	2.0			Facility flow revised.	
AR0033758	Fordyce	Jug Creek	0.84	10	15	6.1	6.0		15	20	7	6.1	6.0			DO limit for May-Oct revised.	
AR0048810	Fulton	Red River	0.05	30 (BOD5)	30		2.0		Year-round							TMDL limit for TDS removed. TMDL withdrawn 11/9/2018.	
AR0050857	Garland WWTP	Red River	0.075	25	90	15	2.0		Year-round							TMDL limit for Chloride and TDS removed from WQMP. TMDL withdrawn 11/9/2018.	
AR0052892	Genoa Central School District	Un. Trib/Beech Creek	0.025	20	20	7	3.0		25	30	12	6.1	3.0			New facility added to 208 Plan.	
AR0036064 (terminated)	Georgia-Pacific Wood Products LLC - Fordyce Plywood Plant (Outfall 001 only)	Jug Creek	Variable	20	30	2	5.0		25	30	2	2	5.0			Permit terminated in 2015. Removed from WQMP.	
AR0021962	Gosnell	State Line Ditch No. 29 / Big Lake Relief Ditch	0.633 HCR	30 (BOD5)	90		2.0		30 (BOD5)	90			2.0			Effluent flow limit for Apr-Nov was revised.	
				Effluent flow not to exceed 10% of upstream flow				Effluent flow not to exceed 30% of upstream flow									
AR0052825	Grand Prairie Bayou Two Public Water Authority - Rolling Hills	Un. Trib/Wattensaw Bayou	0.021	10	15	5	3.0		10	15	10	5.2	3.0			New facility added.	
AR0023833	Gravette	Railroad Hollow Creek	0.56	10	15	6	3.0	1.0	10	15	12	12	3.0	1.0	TP: 1.0 mg/L and 4.7 lb/day	TP limits added.	
AR0001830	Green Bay Packaging, Inc. - Arkansas Kraft Division	Arkansas River	9.19	10090 lb/day BOD5**	14613 lb/day TSS**	**Year-round with the following applicable during July-Sept: 6000 lb BOD5/day for Qs ≤743 cfs; 8.08 lb BOD5/day/cfs for 743 cfs ≤Qs ≤1249 cfs										BOD5 and TSS limits changed, and upper range of upstream flow when BOD5 limit of 8.08 lb/day/cfs applies during July-Sept changed.	
AR0021741	Green Forest	Un. Trib./Dry Creek	4.0	10	15	1	7.0	1.0	10	15	4	1.6	6.0	1.0		Facility flow revised.	
AR0036536	Greenbrier	Greenbrier Creek	0.98	10	15	3	3.0		10	15	6.5	5.6	6.0			DO and NH3 limits were revised.	
AR0042803	Griffithville	Un. Trib./Dogwood Cr	0.05	10	15	12	4.0		10 (BOD5)	15			2.0			Limit changes for CBOD5, NH3-N, DO during May-October	
AR0042609	Harrell	Spring Branch/Blann Creek	0.072	No discharge allowed May-October					25	30	10	10	5.0				TSS limit revised from 90 to 30 mg/L during Nov-Apr.
AR0022381	Heber Springs (Outfall 002)	Little Red River	1.75	20 (BOD5)	20		2.0		Year-round							Outfall 003 added to WQMP.	
	Heber Springs (Outfall 003)	Little Red River	1.75 (max. when upstream ≥ 90 cfs)	No discharge allowed May-October					20 (BOD5)	20			2.0				
AR0039403	HEPOA, LLC	Lake Ouachita	0.089	10	15	5.2	5.0	Report	10	15	14.7	5.2	6.0	Report		DO limit for November-April changed.	
AR0035254	Horseshoe Bend White Oak	Un trib/Strawberry R	0.2	20	20	5	6.0		20	20	10	3.9	6.0		FCB: 3180 Mcol/day (May-Sep) FCB: 15900 Mcol/day (Oct-Apr)	Added TMDL limits for FCB	

Table 1
Arkansas Department of Environmental Quality
Water Quality Management Plan Governor Certification
February 2019

NPDES#	Facility Name	Receiving Stream	Q mgd	Critical Limits (May-Oct.)					Seasonal Limits (Nov-Apr)					TMDL based limits	Changes Prompting Gov Cert	
				CBOD ₅	TSS	NH ₃ -N	DO	TP	CBOD ₅	TSS	NH ₃ -N (Nov-Mar)	NH ₃ -N (April)	DO			TP
AR0033880	Hot Springs STP	Lake Catherine	12	10	15	3.6	5.0	100.1 lb/day	10	15	10	3.6	5.0	100.1 lb/day		NH3-N limits and facility flow changed.
AR0048658	Hunters Glen Owners Association	Un.trib./Main Ditch #1	0.0322	15	20	5	2.0		20 (BOD5)	20			2.0		FCB: 1,211 Mcol/day (year-round)	TMDL limit for FCB was updated.
AR0041335	Jacksonville Wastewater Utility	Bayou Meto	12.31	6.5	15	2	6.5	Report	10	15	4	2.2	6.0	Report		CBOD5, NH3-N, and DO limits were revised.
AR0035491	Lamar	Cabin Creek/Lake Dardanelle	0.106	10 (BOD5)	15		5.0		Year-round							Receiving stream name corrected.
AR0049859	Lerona	Un. Trib./ Big Creek	0.018	15	20	5	2.0		15	20	10	5.6	2.0			NH3 limit for April added, DO limit added.
AR0021806	Little Rock Water Reclamation Authority - Adams Field Water Reclamation Facility	Arkansas River	36	25	30	11.9			30 (BOD5)	30						NH3-N limit removed for April and revised for May-Oct. CBOD5 replaced with BOD5 for April. Facility name change.
AR0040177	Little Rock Water Reclamation Authority - Fourche Creek Water Reclamation Facility	Arkansas River	16	30 (BOD5)	30		2.0		30 (BOD5)	30			2.0		TRC: 1.5 mg/l (Inst. Max) from WQ study, not TMDL based.	Facility name change.
AR0050849	Little Rock Water Reclamation Authority - Little Maumelle Water Reclamation Facility	Arkansas River	4	25	30	15	2.0		25	30	15	15	2.0			Facility name change.
AR0048402	Proedge Properties, LLC - LMJ Trailer Park	Un.trib./Big Creek Ditch	0.024	15	20	5	2.0		20	20	12	5.2	2.0			Facility name change.
AR0050946	London, City of	Lake Dardanelle	0.2	10	15	3.2	5.0	1.0	10	15	10	3.2	5.0	1.0		NH3 limit changed for May-October.
AR0043613	Magnolia	Big Creek	2.5	10	15	2.4	5.0	Report	10	15	6.8	2.4	5.0	Report	Total Lead: 2.67 ug/L and 0.0558 lb/day	TMDL limit for Lead added.
AR0023850	Mammoth Spring	Un.trib./Spring River	0.15	10	15	7	5.0		10	15	10	3.9	7.4			Facility flow was revised.
AR0033430	Marked Tree	St. Francis River	0.42	30 (BOD5)	90		2.0		Year-round							TSS limit corrected to match permit.
AR0041319	Mill Pond Village	Sorrells Cr/Fourche a Loupe Creek/Lake Hamilton	0.023	10	15	4	5.0		10	15	10	5.2	6.0			No record of previous Gov Cert approval
AR0038237	Moro, City of	Hog Tusk Creek/Big Creek	0.05	20	20	5.2	3.0		30 (BOD5)	30			2.0			May-Oct: NH3 and CBOD5 limit added, DO limit revised
AR0035653	Norphlet (Outfall 001)	Un. Trib./Flat Creek	0.18	20	30	2.43 (TMDL-based)	3.0		20	30	17	6.1	2.0		Chloride: 70 mg/L and 105 lb/day Sulfate: 45 mg/L and 68 lb/day TDS: 500 mg/L and 751 lb/day NH3-N: 3.65 lb/day (May-October) NH3-N: 27.01 lb/day (November-April)* *Permit contains more stringent NH3-N mass for Nov-Apr (25.5 lb/day for Nov-Mar, and 9.2 lb/day for April, based on modeling and toxicity standards.	NH3 limit revised in May-October. Added Chloride, Sulfate, TDS concentrations from TMDL.
AR0035653	Norphlet (Outfall 002)	Smackover Creek	0.18	25	30	10.3	2.0		30 (BOD5) Nov-Mar 25 (CBOD5) April	30		11.1	2.0			New outfall 002 added.
AR0020320	North Little Rock - Five Mile Creek	Arkansas River	6.6	25	90		2.0		Year-round							BOD5 limit changed to CBOD5 limit
AR0038288	North Little Rock-White Oak Bayou	Arkansas River	8.5	25	90		2.0	Report	Year-round							BOD5 limit changed to CBOD5 limit
AR0042188	Northern Mobile Home Park NW AR Regional SWMD 2/b/a	Un. Trib./Big Cr. Ditch	0.012	10	15	5	5.0		10	15	10	5.2	5.0			No record of previous Gov Cert approval.
AR0048631 (terminated)	NABORS Landfill Leachate Treatment Plant	Un. trib./Hutch Creek	0.0091	15	20	5	2.0		15	20	10	3.9	2.0			Permit was terminated in 2011. Removed from WQMP.
AR0045837	Oak Grove Heights	Un.trib./Locust Creek	0.3	20	20	5	3.0		20	20	12	5.2	4.0			Facility flow and DO limit for Nov-Apr changed.

Table 1
Arkansas Department of Environmental Quality
Water Quality Management Plan Governor Certification
February 2019

NPDES#	Facility Name	Receiving Stream	Q mgd	Critical Limits (May-Oct.)					Seasonal Limits (Nov-Apr)					TMDL based limits	Changes Prompting Gov Cert	
				CBOD ₅	TSS	NH ₃ N	DO	TP	CBOD ₅	TSS	NH ₃ N (Nov-Mar)	NH ₃ N (April)	DO			TP
AR0035688	Ola	Keeland Creek	0.18	20	20	5	4.0		20	20	12	5.6	2.0		Facility flow changed from 0.15 to 0.18 MGD.	
AR0021580	Osceola	Mississippi River	3.25	30 (BOD5)	90		2.0		Year-round						Facility flow changed from 2.5 to 3.25 mgd.	
AR0020109 (terminated)	USDA Forest Service Ouachita Civ. Cons. Center	Ouachita River	0.024	10	15	5	5.0	2.47	10	15	10	10	5.0	2.47	Permit was terminated in 2017. Removed from WQMP.	
AR0020672	Pea Ridge	Otter Creek	0.9	15	20	3.9	4.0	1.0	15	20	5.0	4.9	6.0	1.0	TP: 1.0 mg/L and 7.5 lb/day TN: 17.0 mg/L and 127.6 lb/day	Facility flow and ammonia limits changed, TP and TN limits added.
AR0052884	MJH Properties, LLC - Jackson Point	Un.Ditch/Blue Branch/Bayou Two Prairie	0.005	10	15	5	2.0		15	20	10	5.6	2.0		Permit number and facility name changed.	
AR0040321	Quitman	Mill Creek	0.15	20	20	4	5.0		20	20	13	5.6	4.0		Facility flow increase. DO limit revised for Nov-Apr.	
AR0001163	Remington Arms Co., Inc	Bayou Meto	HCR (2.27% of upstream)	20 (BOD5)	20		2.0		35 (BOD5)	30			2.0		HCR flow limit added.	
AR0000582	Reynolds Metals Company, LLC - Bauxite Operation	Holly Creek (outfall 009) Hurricane Creek (outfall 028)	variable, HCR											Outfall 009: TDS: 171.5 lb/day per cfs of Saline River flow (daily max) Outfall 028: TDS: 1738 mg/L (monthly average)	Facility added with TMDL limits for TDS	
AR0052086	SWN Production (Arkansas), LLC - SEECO Bee Branch Water Reuse/Recycle Facility	Un. Trib/ Linn Creek	0.168	10	15	5	2.0		10	15	10	5.6	2.0		Facility name changed.	
AR0052175	SWN Production (Arkansas), LLC - SEECO Cleveland Water Reuse/Recycle Facility	Un. Trib/Sucker Creek	0.168	10	15	5	2.0		10	15	10	5.6	2.0		Facility name changed.	
AR0052051	SWN Production (Arkansas), LLC - SEECO Judsonia Water Reuse/Recycle Facility	Un. Trib/Holcomb Branch	0.168	10	15	5	2.0		10	15	10	5.6	2.0		Facility name changed.	
AR0043591	St. Francis	St. Francis River	0.04	30 (BOD5)	90		2.0		Year-round						No record of previous Gov Cert approval.	
AR0050768 (terminated)	Sterling Meadows Sub. WWTP	Un.trib/Greenbrier Ck/Cadron Ck	0.03	15	20	5	5.0		Year-round						Facility removed from WQMP due to no renewal application, permit terminated in 2013.	
AR0046680	Sulphur Rock	Big Creek	0.075	10	15	5	3.0		15	20	10	9.7	6.0		NH3 April limit changed.	
AR0051136	SWEPSCO - John W. Turk, Jr. Power Plant	Little River Un. Trib/Leatherwood Creek	2.16												TMDL limit for TDS was removed from WQMP. TMDL withdrawn 11/9/2018.	
AR0044300	Randall Christy - Statue Road Inn		0.0075	10	15	5	2.0	Report	10	15	10	3.9	6.0	Report	Facility name changed.	
AR0041416	Mentor ABI, LLC dba NeuroRestorative Timber Ridge	Dog Creek/N.Fork Saline	0.012	10	15	5	6.0		10	15	5	5	6.0		Facility name updated.	
AR0048356	Tyson Foods, Inc. - River Valley Animal Foods	Red River	0.42	65	79	50	2.0		Year-round						TMDL limit for TDS was removed from WQMP. TMDL withdrawn 11/9/2018.	
AR0041734	Tyson Poultry -Nashville	Munc Creek/Lake Millwood	1.4	9	20	4	5.0	Report	9	20	4	4	7.4	Report	FCB: 21,198 Mcol/day (Apr-Sep) DM FCB: 105,991 Mcol/day (Oct-Mar) DM	Facility flow changed. TMDL limits for FCB updated.
AR0036013	USCOE - Artie Moore Rec. Area	Lake DeGray	0.013	10	15	5.2	5.0	0.108 lb/d	10	15	14.7	5.2	5.0	0.108 lb/d	TP limits changed from 12 month rolling avg concentration to monthly average mass.	
AR0020222	USCOE Iron Mtn. Rec Area	Lake DeGray	0.014	10	15	5.2	5.0	0.117 lb/day	10	15	14.7	5.2	5.0	0.117 lb/day	TP limits changed from 12 month rolling avg concentration to monthly average mass.	

Table 1
Arkansas Department of Environmental Quality
Water Quality Management Plan Governor Certification
February 2019

NPDES#	Facility Name	Receiving Stream	Q mgd	Critical Limits (May-Oct.)					Seasonal Limits (Nov-Apr)					TMDL based limits	Changes Prompting Gov Cert
				CBOD ₅	TSS	NH ₃ N	DO	TP	CBOD ₅	TSS	NH ₃ N (Nov-Mar)	NH ₃ N (April)	DO		
AR0020231	USCOE Shouse Ford Rec. Area	Lake DeGray	0.02	10	15	5.2	5.0	0.167 lb/day	10	15	14.7	5.2	5.0	0.167 lb/day	TP limits changed from 12 month rolling avg concentration to monthly average mass.
AR0034959	USDI NPS-Buffalo Point Upper Sewer Plant	Un. Ditch/Panther Ck/ Buffalo River	0.015	10	15	5	2.0	1.0	10	15	10	3.9	2.0	1.0	NH3 April limit changed. facility flow changed. TP limit added.
AR0034941	USDI NPS-Buffalo Point Lower Sewer Plant	Buffalo River	0.02	10	15	5	2.0	1.0	10	15	10	10	2.0	1.0	Facility flow changed. TP limit added.
AR0040967	Van Buren North Treatment Plant	Lee Creek	2	10	15	2	6.0		20	20	4	2.2	6.0		DO limit changed for critical season.
AR0052922	Waste Water Management, Inc. - Homestead at the Gap Subdivision	Un. Trib./Palarm Creek	0.024	10	15	7	4.0	1.0	20	30	15	15	2.0	1.0	New facility added to 208 Plan
AR0050814 (terminated)	Wattensaw Subdivision WWTF (Horton Homes)	Wattensaw Bayou/White River	0.33	7	15	2	7.0		4	15	2		8.0		Facility removed from WQMP. Permit terminated in 2011.
AR0020354	Weiner, City of	Un. Trib./Bayou DeView	0.6	15	20	6	6.0		15	20	6	5.2	6.0		No record of previous Gov Cert approval.
AR0041629	Westside Consolidated School District No. 5	Un. Trib./ Bayou DeView	0.03	10	15	5	5.0		10	15	10	5.2	5.0		Receiving stream name corrected.
AR0002917	Weyerhaeuser-Dierks (outfall 002)	Holly Creek	0.053 (May-Oct) 0.158 (Nov-Apr)	15 (BOD5)	35		3.0		21 (BOD5)	35			3.0		Outfalls 002, 003, 004 combined: E. Coli: 86,500 Mcol/day (Oct-Mar) E. Coli: 17,300 Mcol/day (Apr-Sep) Primary season DO limit changed for outfall 003. Flow rates changed for 002 and 003.
AR0002917	Weyerhaeuser-Dierks (outfall 003)	Holly Creek	0.220 (May-Oct) 0.852 (Nov-Apr)	15 (BOD5)	35		3.0		21 (BOD5)	35			4.0		
AR0002917	Weyerhaeuser-Dierks (outfall 004)	Holly Creek	2.23 cfs maximum when Holly Creek is ≥10 cfs and <100 cfs. 11 cfs maximum when Holly Creek ≥100 cfs.	Report (COD)	Report				Report (COD)	Report					
AR0000833 (terminated)	Weyerhaeuser-Mt.Pine	Glazypeau Creek	HCR	50 mg/l BOD5 daily max			6.0		Year-round HCR as % of Upstream Flow			6.0			Removed from WQMP. Permit terminated in 2012.
AR0052621 (terminated)	Waste Water Management, Inc. - Woodsland Edge Subdivision	Un.trib./Little Creek	0.03	15	20	8	3.0	Report	15	20	15	10	3.0	Report	Removed from WQMP Permit terminated on 11/7/2016.
AR0021903	Wynne	Un. Trib-Williams Creek	2.76	12	15	2.1	7.0		12	15	5	2.1	6.0	FCB: 104,500 Mcol/day	Added TMDL limit for FCB