

Category	State	Plant Name	ORIS code	Generator ID	Fuel type	Prime mover type	Nameplate Capacity (MW)	Electric Generation (MWh)	Capacity Utilization	EIA Ratio (EAF) eMMBtu/t otMMBtu	Useful Thermal Output (UTO) (MMBtu)	Net Energy Output (MWh)	Carbon Dioxide Emissions (Unadjusted) (tons)	EPA Emission Rate	Actual Emission Rate	UNITKEEP (CA<25 part of CC with CT>25)	Source Category	Cogen Flag Y/N	Unit Status
COALST	AR	Flint Creek	6138	1	SUB	ST	558.0	3,791,093	77.3%			3,791,093	4,150,944	2,190	2,190		Electric Utility	N	OP
COALST	AR	Independence	6641	1	SUB	ST	900.0	5,293,747	67.0%			5,293,747	5,804,743	2,193	2,193		Electric Utility	N	OP
COALST	AR	Independence	6641	2	SUB	ST	900.0	5,126,271	64.8%			5,126,271	5,996,078	2,339	2,339		Electric Utility	N	OP
COALST	AR	John W Turk Jr Power Plant	56564	1	SUB	ST	609.0	294,975	5.5%			294,975	188,786	1,280	1,280		Electric Utility	N	OP
COALST	AR	Plum Point Energy Station	56456	STG1	SUB	ST	720.0	4,366,528	69.0%			4,366,528	4,944,118	2,265	2,265		Electric Utility/IPP Non-CHP	N	OP
COALST	AR	White Bluff	6009	1	SUB	ST	900.0	4,500,415	56.9%			4,500,415	5,314,862	2,362	2,362		Electric Utility	N	OP
COALST	AR	White Bluff	6009	2	SUB	ST	900.0	5,005,802	63.3%			5,005,802	5,897,951	2,356	2,356		Electric Utility	N	OP
NGCC	AR	Dell Power Station	55340	CTG1	NG	CT	199.3	201,856	11.5%			201,856	93,122	923	923		Electric Utility	N	OP
NGCC	AR	Dell Power Station	55340	CTG2	NG	CT	199.3	201,856	11.5%			201,856	93,122	923	923		Electric Utility	N	OP
NGCC	AR	Dell Power Station	55340	STG	NG	CA	280.5	284,097	11.5%			284,097	131,062	923	923		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G1	NG	CT	51.0	30,316	6.8%			30,316	15,348	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G2	NG	CT	51.0	30,316	6.8%			30,316	15,348	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G3	NG	CT	51.0	30,316	6.8%			30,316	15,348	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G4	NG	CT	51.0	30,316	6.8%			30,316	15,348	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G5	NG	CT	51.0	30,316	6.8%			30,316	15,348	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G6	NG	CT	51.0	30,316	6.8%			30,316	15,348	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G7	NG	CT	83.5	49,635	6.8%			49,635	25,129	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G8	NG	CA	105.0	62,416	6.8%			62,416	31,599	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Harry L. Oswald	55221	G9	NG	CA	105.0	62,416	6.8%			62,416	31,599	1,013	1,013		Electric Utility	N	OP
NGCC	AR	Hot Spring Generating Facility	55418	CT1	NG	CT	198.9	142,924	8.2%			142,924	62,930	881	881		Electric Utility	N	OP
NGCC	AR	Hot Spring Generating Facility	55418	CT2	NG	CT	198.9	142,924	8.2%			142,924	62,930	881	881		Electric Utility	N	OP
NGCC	AR	Hot Spring Generating Facility	55418	ST1	NG	CA	317.0	227,787	8.2%			227,787	100,295	881	881		Electric Utility	N	OP
NGCC	AR	Magnet Cove	55714	GT1	NG	CT	242.0	836,464	39.3%			836,464	351,046	839	839		Electric Utility	N	OP
NGCC	AR	Magnet Cove	55714	GT2	NG	CT	242.0	836,464	39.3%			836,464	351,046	839	839		Electric Utility	N	OP
NGCC	AR	Magnet Cove	55714	ST1	NG	CA	262.0	905,593	39.3%			905,593	380,058	839	839		Electric Utility	N	OP
NGCC	AR	Pine Bluff Energy Center	55075	CT01	NG	CT	180.0	1,135,758	71.8%	0.53	4,548,660	2,135,610	642,744	602	1,132		IPP CHP	Y	OP
NGCC	AR	Pine Bluff Energy Center	55075	ST01	NG	CA	56.0	353,347	71.8%	0.53	1,415,139	664,412	199,965	602	1,132		IPP CHP	Y	OP
NGCC	AR	Thomas Fitzhugh	201	1	NG	CA	59.0	36,503	7.0%			36,503	20,672	1,133	1,133		Electric Utility	N	OP
NGCC	AR	Thomas Fitzhugh	201	2	NG	CT	126.0	77,956	7.0%			77,956	44,146	1,133	1,133		Electric Utility	N	OP
NGCC	AR	Union Power Partners LP	55380	CTG1	NG	CT	176.0	718,446	46.5%			718,446	311,844	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	CTG2	NG	CT	176.0	718,446	46.5%			718,446	311,844	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	CTG3	NG	CT	176.0	718,446	46.5%			718,446	311,844	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	CTG4	NG	CT	176.0	718,446	46.5%			718,446	311,844	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	CTG5	NG	CT	176.0	718,446	46.5%			718,446	311,844	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	CTG6	NG	CT	176.0	718,446	46.5%			718,446	311,844	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	CTG7	NG	CT	176.0	718,446	46.5%			718,446	311,844	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	CTG8	NG	CT	176.0	718,446	46.5%			718,446	311,844	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	STG1	NG	CA	255.0	1,040,931	46.5%			1,040,931	451,819	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	STG2	NG	CA	255.0	1,040,931	46.5%			1,040,931	451,819	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	STG3	NG	CA	255.0	1,040,931	46.5%			1,040,931	451,819	868	868		Electric Utility/IPP Non-CHP	N	OP
NGCC	AR	Union Power Partners LP	55380	STG4	NG	CA	255.0	1,040,931	46.5%			1,040,931	451,819	868	868		Electric Utility/IPP Non-CHP	N	OP
OGST	AR	Carl Bailey	202	1	NG	ST	120.0	46,502	4.4%			46,502	35,551	1,529	1,529		Electric Utility	N	OP
OGST	AR	Cecil Lynch	167	2	NG	ST	69.0	0	0.0%			0	0	0	0		Electric Utility	N	OS
OGST	AR	Cecil Lynch	167	3	NG	ST	156.2	2,581	0.2%			2,581	3,235	2,507	2,507		Electric Utility	N	SB

Category	State	Plant Name	ORIS code	Generator ID	Fuel type	Prime mover type	Nameplate Capacity (MW)	Electric Generation (MWh)	Capacity Utilization	EIA Ratio (EAF) eMMBtu/t otMMBtu	Useful Thermal Output (UTO) (MMBtu)	Net Energy Output (MWh)	Carbon Dioxide Emissions (Unadjusted) (tons)	EPA Emission Rate	Actual Emission Rate	UNITKEEP (CA<25 part of CC with CT>25)	Source Category	Cogen Flag Y/N	Unit Status
OGST	AR	Hamilton Moses	168	1	NG	ST	69.0	0	0.0%			0	No data	0	0		Electric Utility	N	OS
OGST	AR	Hamilton Moses	168	2	NG	ST	69.0	0	0.0%			0	No data	0	0		Electric Utility	N	OS
OGST	AR	Harvey Couch	169	2	NG	ST	156.2	-626	0.0%			-626	0	0	0		Electric Utility	N	SB
OGST	AR	Lake Catherine	170	1	NG	ST	40.0	35	0.0%			35	62	3,556	3,556		Electric Utility	N	SB
OGST	AR	Lake Catherine	170	2	NG	ST	40.0	2	0.0%			2	170	170,054	170,054		Electric Utility	N	SB
OGST	AR	Lake Catherine	170	3	NG	ST	119.5	887	0.1%			887	2,253	5,080	5,080		Electric Utility	N	SB
OGST	AR	Lake Catherine	170	4	NG	ST	552.5	612,047	12.6%			612,047	436,567	1,427	1,427		Electric Utility	N	OA
OGST	AR	McClellan	203	1	NG	ST	136.0	199,295	16.7%			199,295	144,437	1,449	1,449		Electric Utility	N	OP
OGST	AR	Robert E Ritchie	173	1	NG	ST	359.0	-158	0.0%			-158	0	0	0		Electric Utility	N	OS
OGST	AR	Robert E Ritchie	173	2	NG	ST	544.6	-95	0.0%			-95	0	0	0		Electric Utility	N	SB
Dataset compiled using methodology and sources described in EPA's Description of 2012 Unit-Level Data using eGRID Methodology Technical Support Document																			
Sources: EIA 923, EIA 860, Air Markets Program Division																			