



**ENVIRONMENTAL
QUALITY**

WHAT THE NEW UNDERGROUND STORAGE TANK REQUIREMENTS IN RULE 12 WILL MEAN TO YOU:

- Walk-through inspections are required every 30 days.
- Release detection equipment must be tested annually.
- Spill protection (spill buckets) must be tested on or before October 13, 2021, then every 3 years thereafter.
- Sumps and under dispenser containment installed after July 2007 must be tested on or before October 13, 2021, then every 3 years thereafter.
- Overfill prevention equipment must be tested on or before October 13, 2021, then every 3 years thereafter.
- Release detection requirements apply to:
 - emergency generator tanks
 - field constructed tanks
 - airport hydrant systems

This equipment is no longer exempt.

DEQ's mission is to protect, enhance, and restore the natural environment for the well-being of all Arkansans.

CONTACTS

NAME	TITLE	PHONE
Louis Chacon	Inspector Supervisor	501.682.0985
Amy Schluterman	Licensing and Training	501.682.0993
Jacqueline Trotta	Trust Fund Administrator	501.682.0632